

BUILDING SAFETY CERTIFICATE

No. 110

Dated: 8.8.2025

It is certified that the existing building of **BUXI JAGABANDHU ENGLISH MEDIUM SCHOOL** (name of the building or premises) at **M-15, BJB Nagar, Bhubaneswar-751014, Odisha** is having block(s) / Floor(s) as per details below :

Details of Block(s) in School	Block (1)	Block (2)
No. of Floor(s) in the Block	G + 3	G + 3

The building is owned / occupied by **BUXI JAGABANDHU ENGLISH MEDIUM SCHOOL** have complied with the Building Safety requirements in accordance with National Building code Rules, and verified by the officers concerned of **R & B Department, Section-III, Bhubaneswar, Govt. of Odisha** on 8/8/2025 (Date of inspection) in the presence of **Ms. Sandhya Jena, Principal, BJEM School, M-15, BJB Nagar, Bhubaneswar-751014** (Name & Address of the Manager / Secretary or his representative) and that the building / premises is fit for occupancy for running school with effect from 9/8/2025 for a period of one year years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Ramp & Railing provided for physically handicapped students.
2. Stair case width is 1.50 mtr. Rise of steps is 0.15 mtr, tread is 0.30 mtr.
3. Ceiling height from floor measured and it is 3.45 mtr.
4. Paved roads available for movement of fire engine around building.

Issued on 8/8/2025 at **Bhubaneswar** by

*Strike out whichever is not applicable. In case of blocks is more than six use separate sheet for detail.

Signature with seal: [Signature]
Name: Babula Patra Assistant Engineer
Designation : A.E. (civil) R&B, Section-III
Name & Address of the Department / Office" of the
A.E Section III, Kalpana. Bhubaneswar

[Signature] Manager
[Signature] Principal
B.J. English Medium School
Bhubaneswar-14